

## INFORMATION SHEET FOR AIR CONDITIONERS, EXCEPT DOUBLE DUCTS AND SINGLE DUCTS<sup>(5)</sup>

As by comission communication in the framework of ecodesign requirements for air conditioners and comfort fans (EU Regulation no. 206/2012) and of energy labelling of air conditioners - (EU Regulation no. 626/2011).

#### MODEL: X3I ECO PLUS 70 SH / X3I ECO PLUS 70 HL WF

		```	/	Heating (Average)(-10°C)			Y
Cooling Heating		Y Y		Heating (Warmer)(+2°C)		Y Y	
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency	0555	0.5	
Cooling Heating (Average)(-10°C)	Pdesignc Pdesignh	7,0 6,4	kW kW	Cooling Heating (Average)(-10°C)	SEER SCOP (A)	6,5 4,0	-
Heating (Warmer)(+2°C)	Pdesignh	6,9	kW	Heating (Warmer)(+2°C)	SCOP (W)	5,1	
Heating (Colder)(-22°C)	Pdesignh	6,3	kW	Heating (Colder)(-22°C)	SCOP (C)	3,3	-
Declared capacity (*) for cooling butdoor temperature Tj	ı, at indoor temp	erature 27(19)	°C and	Declared Energy efficiency ratio (*) outdoor temperature Tj	for cooling, at indoo	r temperature 27	/(19)°C and
īj = 35°C	Pdc	7,03	kW	Tj = 35°C	EERd	3,60	-
j = 30°C	Pdc	5,09	kW	Tj = 30°C	EERd	5,20	-
ſj = 25°C	Pdc	3,21	kW	Tj = 25°C	EERd	7,34	-
-j = 20°C	Pdc	2,68	kW	Tj = 20°C	EERd	11,76	-
eclared capacity (*) for heating emperature 20°C and outdoor t	-	on, at indoor		Declared Coefficient of Performance temperature 20°C and outdoor tem		erage season, at	indoor
⁻j = -7°C	Pdh	5,79	kW	Tj = -7°C	COPd	2,62	-
[j = 2°C	Pdh	3,61	kW	Tj = 2°C	COPd	4,21	-
¯j = 7°C ¯j = 12°C	Pdh Pdh	2,21	kW kW	Tj = 7°C Tj = 12°C	COPd COPd	4,93 5,80	
[] = 12°C	Pan Pdh	5,79	kW	Tj = 12°C	COPd	2,62	
j = operating limit temperature	Pdh	6,24	kW	Tj = operating limit temperature	COPd	1,79	-
Declared capacity (*) for heating	÷					, , , , , , , , , , , , , , , , , , ,	indoor tom-
0°C and outdoor temperature T			kW	<b>20°C and outdoor temperature Tj</b> Ti = $2^{\circ}C$			indoor tempe
j = 2 C j = 7°C	Pdh	7,23 4,45	kW	$T_{j} = 2 C$	COPd	2,64 4,88	
[j = 12°C	Pdh	2,02	kW	Tj = 12°C	COPd	5,85	-
j = bivalent_temperature	Pdh	7,23	kW	Tj = bivalent temperature	COPd	2,64	-
j = operating limit temperature	Pdh	7,23	kW	Tj = operating limit temperature	COPd	2,64	•
Declared capacity (*) for heating / Colder season, at indoor temperature 20°C and outdoor temperature Tj				Declared Coefficient of Performance (*) for heating / Colder season, at indoor tempera 20°C and outdoor temperature Tj			
-j = -7°C	Pdh	3,87	kW	Tj = -7°C	COPd	2,97	-
-j = 2°C	Pdh	2,33	kW	Tj = 2°C	COPd	4,15	-
j = 7°C	Pdh	1,73	kW	Tj = 7°C	COPd	4,66	-
j = 12°C j = bivalent temperature	Pdh Pdh	1,82 6,56	kW kW	Tj = 12°C Tj = bivalent temperature	COPd COPd	5,61 1,84	-
r = operating limit temperature	Pdh	5,99	kW	Ti = operating limit temperature	COPd	1,79	-
īj =-15°C	Pdh	-	kW	Tj =-15°C	COPd	-	-
Bivalent temperature				Operating limit temperature			
leating (Average)	Tbiv	-7	°C	Heating (Average)	Tol	-7	°C
Heating (Warmer)	Tbiv	2	°C	Heating (Warmer)	Tol	2	°C
Heating (Colder)	Tbiv	-15	°C	Heating (Colder)	Tol	-20	°C
Power consumption of cycling				Efficiency of cycling			
Cooling	Pcycc	nd	kW	Cooling	EERcyc	na	-
leating	Pcych	nd	kW	Heating	COPcyc	na	-
Degradation coefficient cooling(**)	Cdc	0,25	-	Degradation coefficient heating(**)	Cdh	0,25	-
Electric power input in power modes other than "active mode"				Seasonal electricity consumption			
Off mode	P <sub>OFF</sub>	0,000547	W	Cooling	Q <sub>CE</sub>	377	kWh/a
Standby mode	P <sub>SB</sub>	0,000547	W	Heating (Average)(-10°C)	Q <sub>HE</sub> /A	2240	kWh/a
hermostat-off mode	P <sub>TO</sub>	0,00235/0, 0048	W	Heating (Warmer)(+2°C)	Q <sub>HE</sub> /W	1894	kWh/a
Crankcase heater mode	Р <sub>ск</sub>	0	W	Heating (Colder)(-22°C)	Q <sub>HE</sub> /C	4009	kWh/a
Capacity control type				Other items			
Fixed		١		Sound power level (indoor/outdoor)	L <sub>WA</sub>	63/67	dB(A)
Staged		1		Refrigerant type	0	R32	14.00
/ariable		Y	ſ	Global warming potential Rated air flow (indoor/outdoor)	GWP	675 1250/3200	KgCO <sub>2</sub> eo m <sup>3</sup> /h
				ARGOCLIMA SPA - Vi	a A Varo 35 A		
For more detailed information					u A. vai 0,00 * A		/******

(\*\*) If default Cd= 0,25 is chosen, then results from cycling tests are not required. Otherwise either the heating or cooling cycling test value is required



# **Product Fiche**

Model: X3I ECO PLUS 70 SH / X3I ECO PLUS 70 HL WF

Manufacturer : ARGOCLIMA SPA - via Alfeno Varo, 35 - Alfianello (BS) - Italy;

Sound power level (indoor unit / outdoor unit): 63 / 67 dB(A);

#### Refrigerant: R32

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 675. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO<sub>2</sub>, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

Cooling mode SEER: 6.5

Energy efficiency class: A++

Pdesignc: 7.0 kW

Annual electricity consumption 377 kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

### Heating mode

Climate type: Average (-10°C) / Warmer (+2°C) / Colder (-22°C)

SCOP: 4,0/5,1/3,3

#### Energy efficiency class: A+/A+++/B

#### Pdesignh: 6,4/6,9/6,3 kW

The back up heating capacity for SCOP calculation: 0/0/0,8 kW.

Annual electricity consumption **2240/1894/4009** kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.