

INFORMATION SHEET FOR AIR CONDITIONERS, EXCEPT DOUBLE DUCTS AND SINGLE DUCTS⁽⁵⁾

As by Comission Communication in the framework of ecodesign requirements for air conditioners and comfort fans (EU Regulation no. 206/2012) and of energy labelling of air conditioners - (EU Regulation no. 626/2011)

Function to which information applies				If information applies to heating: heating season to which information relates.			
Cooling		Y		Heating (Average)(-10°C) Heating (Warmer)(+2°C) Heating (Colder)(-22°C)		Y Y N	
Heating		Y					
Item	symbol	value	unit	Item	symbol	value	unit
Design load		•		Seasonal efficiency			
Cooling	Pdesignc	6,7	kW	Cooling	SEER	6,53	_
Heating (Average)(-10°C)	Pdesignh	5,7	kW	Heating (Average)(-10°C)	SCOP (A)	4,09	_
Heating (Warmer)(+2°C)	Pdesignh	7,0	kW	Heating (Warmer)(+2°C)	SCOP (W)	5,27	
Heating (Colder)(-22°C)	Pdesignh	-	kW	Heating (Colder)(-22°C)	SCOP (C)	-	-
Declared capacity (*) for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj				Declared Energy efficiency ratio (*) for cooling, at indoor temperature 27(19)°C an outdoor temperature Tj			
Tj = 35°C	Pdc	6,46	kW	Tj = 35°C	EERd	2,99	-
Tj = 30°C	Pdc	4,47	kW	Tj = 30°C	EERd	4,99	-
Tj = 25°C	Pdc	2,98	kW	Tj = 25°C	EERd	7,29	-
Tj = 20°C	Pdc	1,73	kW	Tj = 20°C	EERd	13,45	-
Declared capacity (*) for heating 20°C and outdoor temperature	e Tj			Declared Coefficient of Performar temperature 20°C and outdoor ter	nperature Tj		at indoor
Tj = -7°C	Pdh	4,74	kW	Tj = -7°C	COPd	2,56	-
Tj = 2°C	Pdh	2,89	kW	Tj = 2°C	COPd	4,14	-
Tj = 7°C	Pdh	2,18	kW	Tj = 7°C	COPd	5,25	-
Tj = 12°C	Pdh	1,79	kW	Tj = 12°C	COPd	6,32	-
Tj = bivalent_temperature	Pdh	4,74	kW	Tj = bivalent temperature	COPd	2,56	-
Tj = operating limit temperature	Pdh	5,31	kW	Tj = operating limit temperature	COPd	2,18	-
Declared capacity (*) for heating / Warmer season, at indoor temperature 20°C and outdoor temperature Tj				Declared Coefficient of Performance (*) for heating / Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Tj = 2°C	Pdh	6,86	kW	Tj = 2°C	COPd	2,55	-
Tj = 7°C	Pdh	4,14	kW	Tj = 7°C	COPd	4,67	-
Tj = 12°C	Pdh	2,15	kW	Tj = 12°C	COPd	6,64	-
Tj = bivalent_temperature	Pdh	6,86	kW	Tj = bivalent temperature	COPd	2,55	-
Tj = operating limit temperature	Pdh	6,86	kW	Tj = operating limit temperature	COPd	2,55	-
rj – operating innit temperature				Declared Coefficient of Performance (*) for heating / Colder season, at indoor temperature 20°C and outdoor temperature Tj			
Declared capacity (*) for heatin	-	at indoor tem	perature			Colder season, a	t indoor
Declared capacity (*) for heating 20°C and outdoor temperature	Pdh	at indoor tem	perature kW	temperature 20°C and outdoor ter	COPd	Colder season, a	t indoor -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C	Pdh Pdh		kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C	nperature Tj		
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C	Pdh Pdh Pdh Pdh	-	kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C	COPd COPd COPd COPd	-	-
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C	Pdh Pdh Pdh Pdh Pdh		kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C	COPd COPd COPd COPd COPd	-	- -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature	Pdh Pdh Pdh Pdh Pdh Pdh		kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature	COPd COPd COPd COPd COPd COPd COPd	-	
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature	Pdh	- - -	kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature	COPd COPd COPd COPd COPd COPd COPd COPd	- - - -	- - -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature	Pdh Pdh Pdh Pdh Pdh Pdh		kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature	COPd COPd COPd COPd COPd COPd COPd	- - - -	- - - -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Bivalent temperature	Pdh		kW kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature	COPd COPd COPd COPd COPd COPd COPd COPd	- - - -	
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Bivalent temperature Heating (Average)	Pdh	- - - - - - -	kW kW kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature Heating (Average)	COPd COPd COPd COPd COPd COPd COPd COPd	- - - - - - -	- - - - - - -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Bivalent temperature Heating (Average) Heating (Warmer)	Pdh	- - - - - - - - - - - - - - - -	kW kW kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature Heating (Average) Heating (Warmer)	COPd COPd COPd COPd COPd COPd COPd COPd	- - - - -	- - - - - - - -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Bivalent temperature Heating (Average) Heating (Warmer)	Pdh	- - - - - - -	kW kW kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature Heating (Average)	COPd COPd COPd COPd COPd COPd COPd COPd	- - - - - - -	- - - - - - -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder)	Pdh	- - - - - - - - - - - - - - - -	kW kW kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature Heating (Average) Heating (Warmer)	COPd COPd COPd COPd COPd COPd COPd COPd	- - - - - - - - - - 2	- - - - - - - -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling	Pdh	- - - - - - - - - - - - - - - -	kW kW kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder)	COPd COPd COPd COPd COPd COPd COPd COPd	- - - - - - - - - - 2	- - - - - - - -
Declared capacity (*) for heating 20°C and outdoor temperature Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = -15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling Cooling Heating Heating	Pdh		kW kW kW kW kW kW	temperature 20°C and outdoor ter Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling	COPd COPd COPd COPd COPd COPd COPd COPd		- - - - - - - - - *C

Crankcase heater mode P_{CK} W Heating (Colder)(-22°C) Q_{HE}/C kWh/a Capacity control type Other items Fixed L_{WA} N Sound power level (indoor/outdoor) 63/66 dB(A) Staged Ν R32 Refrigerant type Variable Υ GWP 675 KgCO₂eq. Global warming potential 1300 m³/h Rated air flow (indoor/outdoor)

Cooling

Seasonal electricity consumption

Heating (Average)(-10°C)

Heating (Warmer)(+2°C)

ARGOCLIMA SPA - Via A. Varo,35 - Alfianello (BS) - ITALY - www.argoclima.com

 Q_{CE}

 Q_{HE}/A

Q_{HE}/W

359

1950

1859

kWh/a

kWh/a

kWh/a

Electric power input in power modes other than "active mode"

 P_{OFF}

 P_{SB}

 P_{TO}

Off mode

Standby mode

Thermostat-off mode

For more detailed information

W

W

W

0,6

51,4/13,0

⁽⁵⁾ For multisplit appliances, data shall be provided at a Capacity ratio of 1.

^(**) If default Cd= 0,25 is chosen, then results from cycling tests are not required. Otherwise either the heating or cooling cycling test value is required



Product Fiche

Model: CLIMADESIGN 24000 UE / CLIMADESIGN 24000 UI

Manufacturer: ARGOCLIMA SPA - via Alfeno Varo, 35 - Alfianello (BS) - Italy;

Sound power level (indoor unit / outdoor unit): 63 / 66 dB(A);

Refrigerant: R32

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 675. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

Cooling mode

SEER: 6,5

Energy efficiency class: A++

Pdesignc: 6,7 kW

Annual electricity consumption **359** kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

Heating mode

Climate type: Average (-10°C) / Warmer (+2°C)

SCOP: 4,1/5,2/-

Energy efficiency class: A+/A+++/-

Pdesignh: 5,7/7,0/- kW

The back up heating capacity for SCOP calculation: # kW.

Annual electricity consumption **1950/1859/-** kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.