

INFORMATION SHEET FOR AIR CONDITIONERS, EXCEPT DOUBLE DUCTS AND SINGLE DUCTS (5)

As by Comission Communication in the framework of ecodesign requirements for air conditioners and comfort fans (EU Regulation no. 206/2012) and of energy labelling of air conditioners - (EU Regulation no. 626/2011)

MODEL: NEWAGE PLUS 18000 UE / NEWAGE PLUS 18000 UI

	plies			If information applies to heating: he	eating season to	which informati	on relates.
Cooling		,	Y	Heating (Average)(-10°C)			Υ
Heating		Y		Heating (Warmer)(+2°C) Heating (Colder)(-22°C)		Y N	
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
Cooling	Pdesignc	5,1	kW	Cooling	SEER	6,7	
Heating (Average)(-10°C)	Pdesignh	3,3	kW	Heating (Average)(-10°C)	SCOP (A)	4,0	_
leating (Warmer)(+2°C)	Pdesignh	3,6	kW	Heating (Warmer)(+2°C)	SCOP (W)	5,3	-
leating (Colder)(-22°C)	Pdesignh	-	kW	Heating (Colder)(-22°C)	SCOP (C)	-	-
Declared capacity (*) for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj				Declared Energy efficiency ratio (*) for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj			
j = 35°C	Pdc	4,87	kW	Tj = 35°C	EERd	2,88	-
j = 30°C	Pdc	3,47	kW	Tj = 30°C	EERd	4,64	-
j = 25°C j = 20°C	Pdc Pdc	2,37 1,60	kW kW	Tj = 25°C Tj = 20°C	EERd EERd	8,19 14,23	-
eclared capacity (*) for heating / 0°C and outdoor temperature Tj		<u> </u>		Declared Coefficient of Performanc temperature 20°C and outdoor tem	e (*) for heating /		n, at indoor
ï = -7°C	Pdh	2,68	kW	Tj = -7°C	COPd	2,57	
Tj = 2°C	Pdh	1,69	kW	Tj = 2°C	COPd	4,11	-
j = 7°C	Pdh	1,20	kW	Tj = 7°C	COPd	5,01	-
j = 12°C	Pdh	1,18	kW	Tj = 12°C	COPd	6,52	-
j = bivalent_temperature	Pdh	3,25	kW	Tj = bivalent temperature	COPd	2,26	-
j = operating limit temperature	Pdh	2,68	kW	Tj = operating limit temperature	COPd	2,57	-
Declared capacity (*) for heating / Warmer season, at indoor temperature 20°C and outdoor temperature Tj				Declared Coefficient of Performance (*) for heating / Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
j = 2°C	Pdh	3,29	kW	Tj = 2°C	COPd	3,16	-
j = 7°C	Pdh	2,16	kW	Tj = 7°C	COPd	5,02	-
j = 12°C	Pdh	1,18	kW	Tj = 12°C	COPd	6,52	-
j = bivalent temperature	Pdh	3,29	kW	Tj = bivalent temperature	COPd	3,16	-
eclared capacity (*) for heating /	Pdh Colder season, a	3,29	kW	Tj = operating limit temperature Declared Coefficient of Performance temperature 20°C and outdoor 20°C and 00°C a		3,16 Colder season,	at indoor
Declared capacity (*) for heating / 0°C and outdoor temperature Tj					e (*) for heating /	·	at indoor
eclared capacity (*) for heating / 0°C and outdoor temperature Tj j = -7°C	Colder season, a		perature	Declared Coefficient of Performance temperature 20°C and outdoor 20°C a	e (*) for heating / perature Tj	Colder season,	
veclared capacity (*) for heating / 0°C and outdoor temperature Tj j = -7°C j = 2°C j = 7°C	Pdh Pdh Pdh Pdh	t indoor tem	kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperatu	ce (*) for heating / perature Tj COPd COPd COPd	Colder season,	-
Declared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 12°C	Pdh Pdh Pdh Pdh Pdh	t indoor tem	kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperatu	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd	Colder season,	-
Declared capacity (*) for heating / 0°C and outdoor temperature Tj j = -7°C j = 2°C j = 7°C j = 12°C j = bivalent temperature	Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh	t indoor tem	kW kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 2°C Tj = -7°C Tj = 7°C Tj = 12°C Tj = bivalent temperature	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd	Colder season,	- - - -
Declared capacity (*) for heating / 10°C and outdoor temperature Tj	Pdh	t indoor tem	kW kW kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 2°C Tj = 2°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP	Colder season,	- - -
Declared capacity (*) for heating / 20°C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C	Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh	t indoor tem	kW kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 2°C Tj = -7°C Tj = 7°C Tj = 12°C Tj = bivalent temperature	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd	Colder season,	- - - - -
Declared capacity (*) for heating // 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 12°C = bivalent temperature = operating limit temperature = -15°C = -15°C	Pdh	t indoor tem	kW kW kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 2°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP	Colder season,	- - - - -
leclared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 12°C = bivalent temperature = operating limit temperature = -15°C	Pdh	t indoor tem	kW kW kW kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 2°C Tj = -7°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP	Colder season,	- - - - - - -
Declared capacity (*) for heating / 0°C and outdoor temperature Tj	Pdh		kW kW kW kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 20°C Tj = -7°C Tj = 2°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature Heating (Average)	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		- - - - - -
Declared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 12°C = bivalent temperature = operating limit temperature = -15°C	Pdh		kW kW kW kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperatu	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		- - - - - - -
Declared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 12°C = bivalent temperature = operating limit temperature = -15°C	Pdh		kW kW kW kW kW kW kW	Declared Coefficient of Performance temperature 20°C and outdoor temperatu	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		- - - - - - -
leclared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 12°C = bivalent temperature = operating limit temperature = -15°C	Pdh		kW kW kW kW kW kW c°C	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 20°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		- - - - - - - - *C *C
Declared capacity (*) for heating / 10°C and outdoor temperature Tj	Pdh		kW k	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 20°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		- - - - - - - °C °C °C
Declared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 12°C = 12°C = bivalent temperature = operating limit temperature =	Pdh		kW k	Declared Coefficient of Performance temperature 20°C and outdoor temperatu	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		- - - - - - - *C *C
peclared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C	Pdh		kW k	Declared Coefficient of Performance temperature 20°C and outdoor 20°C	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		- - - - - - - *C *C
lectared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 10°C	Pdh		kW c°C c°C c°C	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 20°C Tj = 7°C Tj = 7°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd Tol Tol Tol Tol Tol Tol Tol COPd COPd COPd COPd		- - - - - - - °C °C °C
leclared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 12°C = 12°C = bivalent temperature = -15°C = claims (Average) = claims (Warmer) = claims (Colder) cooling = claims (eating temperature of the color of the co	Pdh		kW www.	Declared Coefficient of Performance temperature 20°C and outdoor 20°C and o	ee (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd Tol Tol Tol Tol Tol Tol QCE QHE/A		
Declared capacity (*) for heating / 10°C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C	Pdh		kW www.	Declared Coefficient of Performance temperature 20°C and outdoor temperature 20°C and outdoor temperature 20°C Tj = 7°C Tj = 7°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling	ce (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd Tol Tol Tol Tol Tol Tol COPd COPcyc COPcyc COH		- - - - - - - °C °C °C
Declared capacity (*) for heating / 0°C and outdoor temperature Tj = -7°C = 2°C = 7°C = 12°C = 12°C = operating limit temperature = operating limit temperature = operating limit temperature = -15°C	Pdh		kW www.	Declared Coefficient of Performance temperature 20°C and outdoor 20°C and o	EERCYC COPCYC COPCY COPCYC COP		
Declared capacity (*) for heating / 10°C and outdoor temperature Tj	Pdh		kW www.	Declared Coefficient of Performance temperature 20°C and outdoor 20°C and o	EE (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		
Declared capacity (*) for heating / 20°C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 2°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Sivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling Cooling Heating Degradation coefficient cooling(**) Electric power input in power mo Off mode Standby mode Thermostat-off mode Capacity control type	Pdh		kW k	Declared Coefficient of Performance temperature 20°C and outdoor 20°C	EERCYC COPCYC COPCY COPCYC COP		
Declared capacity (*) for heating / 20°C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = 10°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling Cooling Heating Degradation coefficient cooling(**) Electric power input in power mo Dff mode Standby mode Thermostat-off mode Crankcase heater mode Capacity control type Fixed Staged	Pdh		kW k	Declared Coefficient of Performance temperature 20°C and outdoor 20°C	EE (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		
Tj = operating limit temperature Declared capacity (*) for heating / 20°C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj =-15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling Cooling Heating Degradation coefficient cooling(**) Electric power input in power mo Off mode Standby mode Thermostat-off mode Crankcase heater mode Capacity control type Fixed Staged Variable	Pdh		kW k	Declared Coefficient of Performance temperature 20°C and outdoor 20°C	EE (*) for heating / perature Tj COPd COPd COPd COPd COPd COPd COPd COP		

www.argoclima.com

⁽⁵⁾ For multisplit appliances, data shall be provided at a *Capacity ratio* of 1.

(**) If default Cd= 0,25 is chosen, then results from cycling tests are not required. Otherwise either the heating or cooling cycling test value is required



Product Fiche

Model: NEWAGE PLUS 18000 UE / NEWAGE PLUS 18000 UI

Manufacturer: ARGOCLIMA SPA - via Alfeno Varo, 35 - Alfianello (BS) - Italy;

Sound power level (indoor unit / outdoor unit): 57 / 62 dB(A);

Refrigerant: R32

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 675. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

Cooling mode

SEER: 6,7

Energy efficiency class: A++

Pdesignc: 5,1 kW

Annual electricity consumption **267 kWh** per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

Heating mode

Climate type: Average (-10°C) / Warmer (+2°C)

SCOP: 4,0/5,3/-

Energy efficiency class: A+/A+++/-

Pdesignh: 3,3/3,6/- kW

The back up heating capacity for SCOP calculation: # kW

Annual electricity consumption 1155/951/- kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.